


**NOTES:**

1. "D" = ROOF PANEL THICKNESS (AVAILABLE THICKNESS = 2.5, 3, 4, 5, OR 6)
2. FILLER INSULATION MATERIAL AND APPLICATION IS SPECIFIED BY THE PROJECT DESIGNER.
3. VALLEY CONDITIONS ARE NOT RECOMMENDED FOR APPLICATIONS WITH ROOF PITCH LESS THAN 3:12.
4. THE VALLEY PAN WIDTH VARIES WITH THE ROOF'S DRAINAGE REQUIREMENTS.
5. RECOMMENDED VALLEY PAN IS 16 GA. MIN. STEEL, WELDED WATER-TIGHT AND COATED OR LINED WITH MEMBRANE.

\*\* THE DETAIL SHOWN IS SUBJECT TO CHANGE WITHOUT NOTICE.



ATAS INTERNATIONAL, INC

Allentown PA  
610-395-8445  
Mesa AZ  
480-558-7210

|          |  |      |  |                         |  |    |     |                      |       |      |
|----------|--|------|--|-------------------------|--|----|-----|----------------------|-------|------|
| REV. NO. |  | DATE |  | DESCRIPTION OF REVISION |  | BY | APP | TITLE<br>Roof-Valley |       |      |
|          |  |      |  |                         |  |    |     | DWG. NO.             | DR    | DATE |
|          |  |      |  |                         |  |    |     | MATERIAL             | APP   | DATE |
|          |  |      |  |                         |  |    |     | SH. SIZE             | SCALE | X:X  |